



**PSM/CTC/1/01 (026) VOL.1**

30<sup>th</sup> March 2026

Dear Bidders,

**RE: ADDENDUM NO. 4**

**TENDER NO. KPA/026/2025-26/ES-SUPPLY OF BATTERIES AND ACCESSORIES (RESERVED FOR PREFERENCE GROUPS)**

=====

Pursuant to clause 7.1 of the tender document, the Authority hereby issues the following clarifications: -

1. The table below shows a response to issues raised by bidders:

| No. | CLARIFICATION REQUEST   | KPA'S RESPONSE  |
|-----|---|---|
| 1.  | For Lithium cell, we have 26650 or 32700. Which type would you need? Different designer quality attracts different prices     | The specified battery is 3.6V LS1450  |
| 2.  | How many years would you need for Battery Management System? Our BMS ranges from 2-5years. Longer BMS attracts a higher price | The (BMS) is not part of the specified requirements, bidders are requested to adhere to the tender document                         |
| 3.  | How many DOD (Depth of Discharge) do you need? (2000-3000times)   | 3000 times is allowed for category E in the table of requirements   |
| 4.  | Which Battery C Rating do you require, 1C or 0.5C?  | For non-starter batteries lowest possible C-rating below 0.5C, while for starter batteries the highest possible CCA-rating over 500 |

**Kenya Ports Authority**

P.O. Box 95009 - 80104 Mombasa, Kenya

Tel: +254 41 2112999 / 2113999

Mobile: +254 709 092999 / 709 093999 / 730 653999

ISDN (041) 2112999 / 2113999 KEBS ISO 9001 Certified Org. No. 087 | KPA: 5023801017

[www.kpa.co.ke](http://www.kpa.co.ke) | KenyaPortsAuthority



Kenya Ports

2. The Schedule of Requirements and the Price Schedule is amended by introducing the following additional requirements

**CATEGORY F: BATTERY REQUIREMENTS FOR KOT II**

| <b>NO.</b> | <b>BATTERY SIZE</b>                      | <b>UNIT MEASURE</b> | <b>UNIT PRICE INCLUSIVE OF LEVY AND VAT</b> |
|------------|--|---------------------|---|
| 1          | GN 50 1.2v 50AH, Nickel Cadmium Battery  | No.                 |   |
| 2          | GN 50 1.2V 200AH, Nickel Cadmium Battery | No.                 |   |
| 3          | 1.2V 20AH, Nickel Cadmium Battery        | No.                 |   |
| 4          | 1.2V 150AH, Nickel Cadmium Battery       | No.                 |   |


**CATEGORY G: MATERIALS FOR ELECTROLYTE SOLUTION**

| <b>NO</b> | <b>MATERIALS FOR ELECTROLYTE SOLUTION</b> | <b>UNIT OF MEASURE</b> | <b>UNIT PRICE INCLUSIVE OF LEVY AND VAT</b> |
|-----------|---|------------------------|---|
| 1         | Lithium Hydroxide Monohydrate             | KG                     |   |
| 2         | Potassium Hydroxide                       | KG                     |   |

Consequently, the closing date for tender submission has been extended to before **1000hours on THURSDAY, 16<sup>TH</sup> APRIL 2026.**

=====

All other conditions of the tender remain the same.



Eveline Shigoli  
 General Manager Supply Chain Management  
**FOR: MANAGING DIRECTOR**